

SUN INDUSTRIAL SERVICES

(An ISO 9001 : 2015 Certified Company)

Works : Plot No. : E-44, M.I.D.C - Chandrapur, Datala Road,
Dist. : Chandrapur - 442 406 (Maharashtra) India
Phone No. : + 91 - 7172 - 287017, + 91 - 7172 - 287018, Fax : + 91 - 7172 - 287018
Email :- sunishq@gmail.com, mkt@sunis.in, Website :- www.sunis.in



BM/CERT
Quality Assessors

Appendix VII

FIRE SAFETY CERTIFICATE

Ref. No: - SIS/FSC/2023/20623

Dated: - 02/06/2023

Certified that the **MOUNT CARMEL CONVENT HIGH SCHOOL** (name of the building or premise) At **MUL ROAD, DIST: CHANDRAPUR (M.S.)** (Address) comprised of **-NIL-** basement(s) and **G+2** owned/occupied by **The Education & Cultural Society** have complied with the Fire Prevention and Fire Safety requirements in accordance with rule of State/UT Fire Service Rules, & Verified by the Officers concerned of Fire Service on **29/05/2023** in the presence of **Nithya, Principal** and that the building premises is fit for occupancy **Educational Building** with effect from **02/06/2023** for a period of **One Years** in accordance with rule and subject to compliance of the conditions,

Issued on 02/06/2023 at Chandrapur by Suraj Rao

*Strike out whichever is not applicable.

SURAJ
PRAKA
SH RAO

Digitally signed
by SURAJ
PRAKASH RAO
Date: 2023.06.02
11:09:37 +05'30

Signature with Seal:
Name: **Mr. Suraj Rao**
Designation: **Proprietor**

To,
Mount Carmel Convent High School
Mul Road, Dist: Chandrapur (M.S.)

Total No. of Fire Extinguisher

- 1) Centrifugal Monoblock Pump-03 Nos
- 2) DOL Starter-02 No
- 3) Hose Reel Drum-09 Nos
- 4) Fire Hydrant Valve-03 Nos
- 5) Fire Brigade Inlet Connection-01 Nos
- 6) Hose Box-03 Nos
- 7) 15 Mtr 63 MM Dia RRL type Fire Hoses-06 Nos
- 8) SS Short Branch Pipe-03 Nos
- 9) Fire Extinguisher ABC 2 Kg-
- 10) Fire Extinguisher ABC 4 Kg-02 Nos
- 11) Fire Extinguisher ABC 5 Kg-11 Nos
- 12) Fire Extinguisher ABC 6 Kg-
- 13) Fire Extinguishers CO2 4.5 Kg-
- 14) Manual Operated Fire Alarm Siren (Fire Bus)-02 Nos
- 15) Fire Bucket-04 Nos
- 16) Signages-06 Nos
- 17) Conventional type Fire Alarm Panel-01 Nos
- 18) Conventional type Manual Call Point-03 Nos
- 19) Conventional type Hooter-03 Nos
- 20) Conventional type Beam Detector-01 Nos



PRINCIPAL

MOUNT CARMEL CONVENT HIGH SCHOOL
MUL ROAD, SHASTRI NAGAR,
CHANDRAPUR - 442401

MANAGER

MOUNT CARMEL CONVENT HIGH SCHOOL,
MUL ROAD, SHASTRI NAGAR,
CHANDRAPUR - 442401



चंद्रपूर शहर महानगरपालिका, चंद्रपूर

क्रमांक : चंशमनपा/अग्निशमन विभाग/2023-1FRCMC-0570

दिनांक : २३/०५/२०२३

अग्निशमन ना-हरकत प्रमाणपत्र

प्रमाणपत्र देण्यात येते की, अग्निसुरक्षा कायद्याचे परीक्षण करण्याकरीता संचालक महाराष्ट्र अग्निशमन सेवा, मुंबई यांनी निश्चित केलेल्या एजन्सी यांनी महाराष्ट्र आग प्रतिबंधक व जीवसंरक्षक उपाययोजना अधिनियम २००६ अंतर्गत, खाली नमुद व्यावसायिक ठिकाणातील अग्निसुरक्षा व्यवस्थेचे परीक्षण (फायर सेफ्टी ऑडीट) व आग प्रतिबंधक उपाययोजनेची तपासणी दिनांक 27-APRIL-2023 रोजी केली. त्यांनी खालील प्रमाणे अग्निप्रतिबंधक उपाययोजना अस्तित्वात असल्याचे प्रमाणित केले आहे.

व्यवसायाचे नाव : **Mount Carmel Convent High School, Chandrapur**
ठिकाण : **Mul Road, Shastri Nagar, Chandrapur**
उपाययोजनेचे विवरण : **फॉर्म 'अ' प्रमाणे**
परिक्षण एजन्सी : **M/s. Sun Industrial Services**
एजन्सीचे लायसन्स क्रं : **MFS/LA/RF-12/RD-11**

अग्निशमन प्रतिबंधक उपाययोजनेची तपासणी दर सहा महिन्यात (जाने / जुलै) चंद्रपूर शहर महानगरपालिका ने निश्चित केलेल्या एजन्सी कडून करवून घेणे व्यावसायिकांना बंधनकारक आहे. सदर प्रमाणपत्र यापुढे नुतनीकरण करतेवेळी चंद्रपूर शहर महानगरपालिका च्या कर विभागाकडून चालू वर्षाचा कर भरणा केल्याची कर पावती जोडणे बंधनकारक असेल.


आयुक्त

चंद्रपूर शहर महानगरपालिका, चंद्रपूर

